



Lampada di emergenza

Emergency light • Eclairage de secours
Notlicht • Lámpara de emergencia




D4

Manuale di Installazione



*Installation manual / Notice technique
Installationshandbuch / Manual de Instalación*

V. 1.3

Istruzioni di montaggio • Installation instruction
Instruction pour le montage • Montageanleitung • Instrucciones de montaje



Schemi elettrici • Wiring diagram
Schémas électriques • Elektrische Schemas • Esquemas eléctricos



Collegare tra loro i morsetti B1 e B2 prima di alimentare la lampada di emergenza e NON scollegarli quando questa è collegata all'alimentazione.

Before powering the emergency lamp, connect B1 and B2 screw terminals together and DO NOT disconnect them as long as it is powered.

Brancher les bornes à vis B1 et B2 entre eux avant d'alimenter l'éclairage de secours et ne pas les débrancher pendant qu'il est alimenté.

Bevor die Notlichter zu versorgen, die Klemmen B1 und B2 miteinander anschließen. Diese Anschließung behalten auch während Versorgung des Notlichts.

Conectar entre ellos los bornes B1 y B2 antes de alimentar la lámpara de emergencia y NO los desconectes cuando ésta está conectada a la alimentación.



Consultare il manuale "**Precauzioni d'uso e sicurezza**"
Refer to the "**Safety and usage precautions**" manual
Consulter manuel technique "**Precautions de securite et d'emploi**"
Handbuch lesen "**Sicherheits- und Gebrauchsanweisung**"
Consulte el manual "**Precaucioned de seguridad**"




www.dmg.it



DMG SpA

Via delle Monachelle, 84/C
00071 POMEZIA (ROMA) • ITALIA
Tel. +39 06930251 • Fax +39 0693025240
info@dmg.it • www.dmg.it



93010224